

	ಬೆಂಗಳೂರು ವಿದ್ಯುತ್ ಸರಬರಾಜು ಕಂಪನಿ ನಿಯಮಿತ (ಕರ್ನಾಟಕ ಸರ್ಕಾರದ ಸಂಪೂರ್ಣ ಸ್ವಾಮ್ಯಕ್ಕೆ ಒಳಪಟ್ಟಿದೆ) Bengaluru Electricity Supply Company Limited
Telephone No. 080-2225 2128 E-Mail gmqs.work@gmail.com, gmqs@bescom.co.in No: BESCOM/GM(QS&S)/DGM-2/AGM-3/BC-35/23-24/2447 Encl:	O/o General Manager (Ele), Quality, Standard and Safety Corporate Office, KR Circle BESCOM, Bengaluru - 560 001 Date: 18 JAN 2024

AMENDMENT-I

- Sub:** Procurement of FRP discharge rod 16 ft, 3 stage.
- Ref:**
1. T.O. Bid Enquiry No: BESCOM/GM(Q,S&S)/2023-24/16.
 2. KPP Potal tender No. BESCOM/2023-24/IND0047.
 3. Paper Notification dated: 31.12.2023.
 4. Pre-bid meeting dated: 10.01.2024.
- *****

The following amendment pertaining to subject bid enquiry is herewith issued consequent to request from the prospective bidders and deliberations during pre-bid meeting.

Sl No.	Document and Clause No.	As existing	As Amended
1	Section II ITT, A. Introduction SI no. 5 Section II Clause 2.0 Submission of tender documents.	Due date for submission of Bids & samples: 19.01.2024, 16:00 Hrs. All the Tender Documents shall be uploaded through Karnataka Public Procurement Portal on or before 19.01.2024, 16:00 Hrs.	Due date for submission of Bids & samples: 25.01.2024, 16:00 Hrs. All the Tender Documents shall be uploaded through Karnataka Public Procurement Portal on or before 25.01.2024, 16:00 Hrs.
2	Section VI : TECHNICAL SPECIFICATION OF FRP DISCHARGE ROD- 16 FEET 3 STAGE, Clause 5., A. point 7	All the required sticks should be provided with Special Spring Loaded self- locking system with Guided couplers. Total Weight of the Discharge Stick should not be more than 4 kgs (weight of the rod: 2.7kg + weight of the cable and bottom earthing clamp is 1.3kg).	All the required sticks should be provided with Special Spring Loaded self- locking system with Guided couplers. Total Weight of the Discharge Stick should not be more than 5.7 kgs (weight of the rod: 2.7kg + weight of the cable and bottom earthing clamp is 2.3kg + weight of electrode along with chain- 0.7kgs).

Sl No.	Document and Clause No.	As existing	As Amended
3	Section VI : TECHNICAL SPECIFICATION OF FRP DISCHARGE ROD-16 FEET 3 STAGE, Clause 5, D. BOTTOM CLAMP/GROUNDING CLAMP:	The bottom end of the Telescopic Stick should be dressed with adequate Hand Grip to prevent the penetration of moisture from underneath, thus making the device completely moisture proof. The Stick should be provided with Aluminium casted Grounding C clamp suitable to grip minimum 30 mm thick. The grounding clamp must be provided with T Bolt for manual tightening.	The bottom end of the Telescopic Stick should be dressed with adequate Hand Grip to prevent the penetration of moisture from underneath, thus making the device completely moisture proof. The Stick should be provided with Aluminium casted Grounding C clamp suitable to grip minimum 30 mm thick. The grounding clamp shall be provided with T Bolt for manual tightening along with a round GI earth electrode of 12mm by 12 inch with a pointed edge on one side of the electrode and other end with GI chain of approximately 1 feet length connecting to the grounding C-clamp.
4	Section VI : TECHNICAL SPECIFICATION OF FRP DISCHARGE ROD-16 FEET 3 STAGE, Clause 6. Packing and Marking :	The each Earthing Stick should be suitably packed in Bag with shoulder strap.	The each Earthing Stick should be suitably packed in " Medium Duty cotton tarpaulin canvas " Bag with Logo and letters of "BESCOM" in English and "ಬೆಸಕಂ" in Kannada on the bag with a shoulder strap.

All other terms & conditions for the subject tender remain unaltered.


(S.T Shanthamallappa)
General Manager(Ele)
QS&S, Corporate Office,
BESCOM

Copy to:-

1. PS to Director (Technical), BESCOM, K.R.Circle, Bangalore, to place before the Director (Technical) for kind information.
2. MF/OC.